





















































































Raporty Statusów Urządzeń

Lp.	Jednostka Sterująca	Global ID	Typ	Status
1	192.168.0.21	0F:AB:34:73:4F:02	CTI 3x64	✓ OK
2	192.168.0.22	09:AB:34:73:4F:02	CTI 3x64	✓ OK
3	192.168.0.23	07:AB:34:73:4F:02	CTI 3x64	✓ OK
4	192.168.0.24	F6:AA:34:73:4F:02	CTI 3x64	✓ OK
5	192.168.0.25	F7:AA:34:73:4F:02	CTI 3x64	✓ OK











































Raporty Statusów Urządzeń

Lp.	Jednostka Sterująca	Urządzenie	Nazwa	Port	Status
1	192.168.0.21	AA16F8	-1pom.rozdz.E	2	 OK
2	192.168.0.21	AA16F9	-1pom.ups E	2	 OK
3	192.168.0.21	AA172E	-1A,kl.s,k/bufetu	2	 OK
4	192.168.0.21	AA1737	-1 B k. pok. 030	2	 OK
5	192.168.0.21	AA2146	-1 wyjście E	2	 OK
6	192.168.0.21	AB05B6	-1 A kuchn wyjE	2	 OK
7	192.168.0.21	AB05B7	-1 A kuch k/0010	2	 OK
8	192.168.0.21	AB05BA	-1E,k.k/mag.A007	2	 OK
9	192.168.0.21	AB05C4	-1B,k.wyj.klsB	2	 OK
10	192.168.0.21	AB05C5	-1B,k.k/garaży	2	 OK
11	192.168.0.21	AB05CD	-1,łącz. wyj B	2	 OK
12	192.168.0.21	AB07D0	-1B,pom.Policji	2	 OK
13	192.168.0.21	AB07D3	-1Bar.zat.k.k/wc	2	 OK
14	192.168.0.21	AB07D5	-1B,p.010k/upsa	2	 OK
15	192.168.0.21	AB07D6	-1B p.014	2	 OK
16	192.168.0.21	AB0915	-1 A kor k/002	2	 OK
17	192.168.0.21	AB092C	-1 A kl. sch. L	2	 OK
18	192.168.0.21	AB0A36	-1 A kuch k/0010	2	 OK
19	192.168.0.21	AB0E26	kl.s arch.zakłB	2	 OK
20	192.168.0.21	AB0E43	-1 A kl. schod.	2	 OK
21	192.168.0.21	AB0F0B	-1 A kor k/003	2	 OK
22	192.168.0.21	AB0F10	-1 A kor k/0004	2	 OK
23	192.168.0.21	AC0217	-1B garaże	2	 OK
24	192.168.0.21	AC0218	-1B garaże	2	 OK
25	192.168.0.21	AC021C	-1B garaże	2	 Ładowanie akumulatora
26	192.168.0.21	AC0270	-1 E kor k/0005	2	 OK
27	192.168.0.21	AC02F8	-1 p.ups B	2	 OK
28	192.168.0.21	AC035B	-1 rozdz.el.E	2	 OK
29	192.168.0.21	AC0365	-1 B kor k/RE	2	 OK
30	192.168.0.21	AC03EA	-1 B kor. k/gar.	2	 OK
31	192.168.0.21	AC0683	-1B p.020	2	 OK
32	192.168.0.21	AC07A4	-1 B kor. k/031	2	 OK
33	192.168.0.21	AC07AE	-1 łącz.wyj.B	2	 OK
34	192.168.0.21	AC07B2	-1B,ar.zatrz.k.	2	 OK
35	192.168.0.21	AC07B7	-1 B 026	2	 Brak połączenia
36	192.168.0.21	AC07CD	-1 B kl. sch.	2	 Awaria źródła światła
37	192.168.0.21	AC07CF	-1 A kuch k/0017	2	 OK
38	192.168.0.21	AC0963	-1 A kl. wyj. B	2	 OK
39	192.168.0.21	ADABAB	-1 rozdz.el.B	2	 OK
40	192.168.0.21	ADABAF	-1 p.upsB	2	 OK
41	192.168.0.21	AA0D6A	0 B kor. k/023	1	 OK
42	192.168.0.21	AA14F8	0 B pok. 002	1	 OK











































Raporty Statusów Urządzeń

Lp.	Jednostka Sterująca	Urządzenie	Nazwa	Port	Status
43	192.168.0.21	AA150C	0 B SR IV	1	 OK
44	192.168.0.21	AA1510	0 B pok. 002	1	 OK
45	192.168.0.21	AA188A	0 B p/037 osk.	1	 OK
46	192.168.0.21	AA1BB4	0 B p/037 osk.	1	 OK
47	192.168.0.21	AA1BB9	0 B pok/037	1	 OK
48	192.168.0.21	AA1BC1	0 B SR IV	1	 OK
49	192.168.0.21	AA1BC5	0 B pok/037	1	 OK
50	192.168.0.21	AA1BCB	0 B p/037 osk.	1	 OK
51	192.168.0.21	AA1BCF	0 B p/037 osk.	1	 OK
52	192.168.0.21	AA1CBE	0 B spocznik-1/0	1	 OK
53	192.168.0.21	AA1CD3	0 B k. pok. 031	1	 OK
54	192.168.0.21	AA1CDD	0 B pok/041	1	 OK
55	192.168.0.21	AB009F	0 B kor k/sr I	1	 OK
56	192.168.0.21	AB05C2	0 B kor k/sr IV	1	 OK
57	192.168.0.21	AB07B9	0 B bramki k. A	1	 OK
58	192.168.0.21	AB0922	0 B SR III	1	 OK
59	192.168.0.21	AB0924	0 B SR II	1	 OK
60	192.168.0.21	AB092F	0 B SR I	1	 Brak połączenia
61	192.168.0.21	AB0E3F	0 B hol k/030	1	 OK
62	192.168.0.21	AC036C	0 B kl. sch. 38	1	 OK
63	192.168.0.21	AC0372	0 B kor. k/016	1	 OK
64	192.168.0.21	AC0376	0 B kor. k/027	1	 OK
65	192.168.0.21	AC0378	0 B kor k/srIII	1	 OK
66	192.168.0.21	AC037C	0 B kor. k/012	1	 OK
67	192.168.0.21	AC0388	0 B kor. k/027	1	 OK
68	192.168.0.21	AC038A	0 B kor. k/012	1	 OK
69	192.168.0.21	AC03B8	0 B pok. 030	1	 OK
70	192.168.0.21	AC03CB	0 B pok. 030	1	 OK
71	192.168.0.21	AC03E3	0 B pok/040	1	 OK
72	192.168.0.21	AC0681	0 B hol k/037	1	 OK
73	192.168.0.21	AC0755	0 B pok/009	1	 OK
74	192.168.0.21	AC0756	0 B pok/016	1	 OK
75	192.168.0.21	AC0758	0 B hol k/030	1	 OK
76	192.168.0.21	AC075C	0 B bramki k. A	1	 OK
77	192.168.0.21	AC0763	0 B bramki k. A	1	 OK
78	192.168.0.21	AC0775	0 B pok/023	1	 OK
79	192.168.0.21	AC077A	0 B pok/023	1	 OK
80	192.168.0.21	AC079D	0 B SR II	1	 OK
81	192.168.0.21	AC07AB	0 B kl.sch k.030	1	 OK
82	192.168.0.21	AC07BC	0 B pok/023	1	 OK
83	192.168.0.21	AC07DD	0 B spocznik	1	 OK
84	192.168.0.21	AC0B1E	0 B pok/023	1	 OK











































Raporty Statusów Urządzeń

Lp.	Jednostka Sterująca	Urządzenie	Nazwa	Port	Status
85	192.168.0.21	AC0B23	0 B p/037 osk.	1	 OK
86	192.168.0.21	AC0B31	0 B kor. k/017	1	 OK
87	192.168.0.21	AC0B37	0 B kor. k/012	1	 OK
88	192.168.0.21	AC0B7B	0 B kor k/srIII	1	 OK
89	192.168.0.21	AC0B7E	0 B spocznik	1	 OK
90	192.168.0.21	ADE97C	0 B kor k/srIV	1	 OK
91	192.168.0.21	ADE982	0 B hol k/030	1	 OK
92	192.168.0.21	ADE98A	0 B pok/009	1	 OK
93	192.168.0.21	ADE98C	0 B pok/037	1	 OK
94	192.168.0.21	ADE98E	0 B pok/037	1	 OK
95	192.168.0.21	ADE993	0 B pok/037	1	 OK
96	192.168.0.21	ADE994	0 B pok/037	1	 OK
97	192.168.0.21	AE67B7	0 B kor. k. kl.	1	 OK
98	192.168.0.21	AE74B4	0 B pok/037	1	 OK
99	192.168.0.21	AE7507	0 B pok/009	1	 OK
100	192.168.0.21	ADABB7	-1 rozdz.el.B	2	 OK
101	192.168.0.21	ADABCD	-1 p.upsE	2	 OK
102	192.168.0.21	ADE7E6	-1 B pok 037	2	 OK
103	192.168.0.21	ADE8CA	-1 A kor k/029	2	 Tryb awaryjny
104	192.168.0.21	ADE8D4	-1B,archk/gar/wi	2	 Awaria akumulatora
105	192.168.0.21	ADE98B	-1E,cls,arch.ks.	2	 OK
106	192.168.0.21	AE6546	-1 A kor k/003	2	 OK
107	192.168.0.21	AE654D	-1 A kor k/004	2	 OK
108	192.168.0.21	AE67B2	-1B k.k/p.020	2	 OK
109	192.168.0.21	AE67C1	-1 A kor k/002	2	 OK
110	192.168.0.21	AE67C2	-1 B gar.wyj.	2	 Ładowanie akumulatora
111	192.168.0.21	AE67C9	-1 wyjście E	2	 OK
112	192.168.0.21	AE67D1	-1 A kor k/0011	2	 OK
113	192.168.0.21	AE67D2	-1 E kor k/0005	2	 OK
114	192.168.0.21	AE74AC	-1 B pok. 026	2	 OK
115	192.168.0.21	AE74AF	-1E koniec koryt	2	 OK
116	192.168.0.21	AE7506	-1 A kor k/0004	2	 OK
117	192.168.0.21	AE7578	-1 B kor k/0024	2	 OK
118	192.168.0.21	AE7579	-1 B pok 037	2	 OK
119	192.168.0.21	AF0E50	-1 A kuch k/0010	2	 OK
120	192.168.0.21	AF0E55	-1B korytarz	2	 OK
121	192.168.0.21	AF0E5B	-1 A kor k/0004	2	 OK
122	192.168.0.21	AE67BB	-1 piwnica	2	 OK
123	192.168.0.22	AA0E31	-1 C RE	1	 OK
124	192.168.0.22	AA1C87	0 C kor. k/011	1	 OK
125	192.168.0.22	AA1CBB	-1 C UPS	1	 OK
126	192.168.0.22	AA1CC4	-1 C kor k/0018	1	 OK











































Raporty Statusów Urządzeń

Lp.	Jednostka Sterująca	Urządzenie	Nazwa	Port	Status
127	192.168.0.22	AA1F3F	0 C pok/002	1	 Awaria źródła światła
128	192.168.0.22	AA1F41	0 C pok/002	1	 OK
129	192.168.0.22	AA1F42	0 C kor k/021	1	 OK
130	192.168.0.22	AA1F44	0 C pok/002	1	 OK
131	192.168.0.22	AA1F45	0 C pok/002	1	 OK
132	192.168.0.22	AB05B8	-1 A kuch wyj.	1	 OK
133	192.168.0.22	AB0916	-1 A kuch posilk	1	 OK
134	192.168.0.22	AB0A32	0 C pok/019	1	 OK
135	192.168.0.22	AB0A34	0 C pok/002	1	 OK
136	192.168.0.22	AB0A3B	0 C kor k/019	1	 Awaria źródła światła
137	192.168.0.22	AB0A3F	0 C pok/019	1	 OK
138	192.168.0.22	AB0A42	0 C pok/019	1	 OK
139	192.168.0.22	AB0E35	-1 A stolowka	1	 OK
140	192.168.0.22	AB0E38	-1 A stolowka	1	 OK
141	192.168.0.22	AC026F	-1 C kor k/0020	1	 OK
142	192.168.0.22	AC036B	0 C kor k/006	1	 OK
143	192.168.0.22	AC0380	-1 C RE	1	 OK
144	192.168.0.22	AC03C0	-1 C UPS	1	 OK
145	192.168.0.22	AC03C9	0 C kor k/014	1	 OK
146	192.168.0.22	AC0400	0 C kl. sch.	1	 OK
147	192.168.0.22	AC07C8	0 C pok/020	1	 OK
148	192.168.0.22	AC07CB	0 C pok/020	1	 OK
149	192.168.0.22	AC0965	0 C sala.konfer.	1	 OK
150	192.168.0.22	AC0B0A	0 C pok/019	1	 OK
151	192.168.0.22	AC0B0C	0 A/C kor k/000	1	 OK
152	192.168.0.22	AC0B15	0 C kor k/014	1	 OK
153	192.168.0.22	AC0B7A	-1 C spocznik	1	 OK
154	192.168.0.22	AE653A	0 C spocznik	1	 OK
155	192.168.0.22	AE653E	-1 C kor k/0003	1	 OK
156	192.168.0.22	AE654F	-1 C kor k/0008	1	 OK
157	192.168.0.22	AE67BF	-1 C kor k/0017	1	 OK
158	192.168.0.22	AE67C3	-1 C kor k/0001	1	 OK
159	192.168.0.22	AE67CC	-1 C kor k/0013	1	 OK
160	192.168.0.22	AE67CF	-1 C kl. sch.	1	 OK
161	192.168.0.22	AE67D3	-1 A kuch bar	1	 OK
162	192.168.0.22	AE74B1	0 C pok/002	1	 OK
163	192.168.0.22	AE74FD	-1 A stol. wej.	1	 OK
164	192.168.0.22	AE74FF	-1 A kuch zmywal	1	 OK
165	192.168.0.22	AE7501	-1 A stol. wyj.	1	 OK
166	192.168.0.22	AF0E4F	-1 C kor k/0020	1	 OK
167	192.168.0.22	AF0E58	-1 A kuch bar	1	 OK
168	192.168.0.22	AF0E5A	-1 A kuch wyj.	1	 OK











































Raporty Statusów Urządzeń

Lp.	Jednostka Sterująca	Urządzenie	Nazwa	Port	Status
169	192.168.0.22	AF0E5D	-1 C spocznik	1	 OK
170	192.168.0.22	AA1C89	2 C kor. k/221	2	 OK
171	192.168.0.22	AA1CBD	1 C kor k/105	2	 OK
172	192.168.0.22	AA1CCC	2 C kor k/209	2	 OK
173	192.168.0.22	AA1CD0	2 C kor. k/222	2	 OK
174	192.168.0.22	AA1CD5	2 C kanc. tajna	2	 OK
175	192.168.0.22	AA1CDC	2 C kor k/225	2	 OK
176	192.168.0.22	AB05B0	2 C kl/s spocz	2	 OK
177	192.168.0.22	AB0E41	1 C kor k/109	2	 OK
178	192.168.0.22	AC0237	1 C spocznik	2	 OK
179	192.168.0.22	AC0242	1 C k/sch spocz	2	 OK
180	192.168.0.22	AC02F6	2 C kor. k/202	2	 OK
181	192.168.0.22	AC035D	1 C kor k/111	2	 OK
182	192.168.0.22	AC0364	2 C kor k/212	2	 OK
183	192.168.0.22	AC03C2	1 C kor k/102	2	 OK
184	192.168.0.22	AC03D7	2 C kor. k/205	2	 OK
185	192.168.0.22	AC03E0	1 C kor k/101	2	 OK
186	192.168.0.22	AC03EB	1 C k/sch	2	 Awaria źródła światła
187	192.168.0.22	AC07C5	2 C kl/s	2	 OK
188	192.168.0.22	AC0B0B	1 C kor k/117	2	 OK
189	192.168.0.22	AC0B7C	1 C kor k/113	2	 OK
190	192.168.0.22	AC0B80	1 C kor k/102	2	 OK
191	192.168.0.22	ADE8C3	2 C kanc. tajna	2	 OK
192	192.168.0.22	AE6522	1 C spocznik	2	 OK
193	192.168.0.22	AE67CE	1 C kor k/106	2	 OK
194	192.168.0.22	AF0E56	2 C kl/s spocz	2	 OK
195	192.168.0.22	AA1D2B	1 B spocznik 0	1	 OK
196	192.168.0.22	AC07B8	-1 kor kuchn,	1	 OK
197	192.168.0.23	AB0EFE	0 A kor portiern	1	 OK
198	192.168.0.23	AB0F0E	0 A łącznik E	1	 OK
199	192.168.0.23	ADE8CD	0 A/E łącznik	1	 OK
200	192.168.0.23	ADE976	-1/0 A spoczn L	1	 OK
201	192.168.0.23	AA1BC3	3 E kor k/303	2	 OK
202	192.168.0.23	AA1CC3	3 E kor k/309	2	 OK
203	192.168.0.23	AA0D41	0 A kor portiern	1	 OK
204	192.168.0.23	AA172F	0 A wej. Gł. P	1	 OK
205	192.168.0.23	AA1CC2	0 E kor k/011	1	 OK
206	192.168.0.23	AA1F3E	0 A wej. Gł. P	1	 OK
207	192.168.0.23	AA2147	0 A wej. Gł. P	1	 OK
208	192.168.0.23	AB05A0	0 A wej. Gł.L	1	 OK
209	192.168.0.23	AB091B	0 A wej. Gł.L	1	 OK
210	192.168.0.23	AB092B	-1/0 A spocz. P	1	 OK











































Raporty Statusów Urządzeń

Lp.	Jednostka Sterująca	Urządzenie	Nazwa	Port	Status
211	192.168.0.23	AB0D0A	0 A wej. Gł.śr.	1	 Awaria źródła światła
212	192.168.0.23	AB0E33	0 A p.ochrony	1	 Awaria źródła światła
213	192.168.0.23	AB0E44	0 A kor k/011	1	 OK
214	192.168.0.23	AB0EFB	0 A kor k/007	1	 OK
215	192.168.0.23	AB0EFF	0 A kor k/020	1	 OK
216	192.168.0.23	AC036E	0 A kor k/009	1	 OK
217	192.168.0.23	AC0371	0 A kor k/016	1	 Awaria źródła światła
218	192.168.0.23	AC037E	0 A wej. Gł.L	1	 Brak połączenia
219	192.168.0.23	AC03B5	0 E kor k/007	1	 OK
220	192.168.0.23	AC03C5	0 A kl. sch. P	1	 OK
221	192.168.0.23	AC03C7	0 E kor k/012	1	 OK
222	192.168.0.23	AC03DB	0 E kor k/003	1	 OK
223	192.168.0.23	AC0682	0 A kor k/017	1	 OK
224	192.168.0.23	AC0B7D	0 E kor k/008	1	 OK
225	192.168.0.23	AC0B8B	-1/0 A spocz. P	1	 OK
226	192.168.0.23	AC0C1C	0 E łącznik A	1	 OK
227	192.168.0.23	ADE983	0 A kor k/015	1	 OK
228	192.168.0.23	ADE987	-1/0 A spoczn L	1	 OK
229	192.168.0.23	ADE990	0 A kl. sch. L	1	 OK
230	192.168.0.23	AE67D8	0 A łącznik E	1	 OK
231	192.168.0.23	AE698F	0 E kor k/006	1	 OK
232	192.168.0.23	AA1CD2	3 B kor k/329	2	 OK
233	192.168.0.23	AA1CD6	3 B kor. k/309	2	 OK
234	192.168.0.23	AA1CD7	3 B kor. k/312	2	 OK
235	192.168.0.23	AA1CD9	3 B kor k/312	2	 OK
236	192.168.0.23	AA1CDF	3 B kor k/322	2	 OK
237	192.168.0.23	AA1D32	3 B/A kl/s spocz	2	 OK
238	192.168.0.23	AA1D33	3 B/A kl/s	2	 OK
239	192.168.0.23	AB05B2	2/3 B spocznik	2	 OK
240	192.168.0.23	AB05BB	3 B kor. k/316	2	 OK
241	192.168.0.23	AB05D3	2/3 B spocznik	2	 OK
242	192.168.0.23	AB0F0C	3 A k/kl. sch. L	2	 OK
243	192.168.0.23	AB0F13	3 A kor k/321	2	 OK
244	192.168.0.23	AB0F14	3 A kor k/314	2	 OK
245	192.168.0.23	AC0367	3 E kor k/301	2	 OK
246	192.168.0.23	AC0379	3 A kor k/319	2	 Tryb awaryjny
247	192.168.0.23	AC0385	3 A kor k/309	2	 Awaria źródła światła
248	192.168.0.23	AC0386	3 A kor k/316	2	 OK
249	192.168.0.23	AC03C6	3 B kor k/326	2	 OK
250	192.168.0.23	AC03C8	3 E kor k/315	2	 Tryb awaryjny
251	192.168.0.23	AC03D6	3 B kor. k/313A	2	 OK
252	192.168.0.23	AC03D8	3 B kor k/315	2	 OK











































Raporty Statusów Urządzeń

Lp.	Jednostka Sterująca	Urządzenie	Nazwa	Port	Status
253	192.168.0.23	AC0769	3 A kor k/312	2	 OK
254	192.168.0.23	AC07D2	2/3 B spocznik	2	 OK
255	192.168.0.23	AC0B16	3 A kor k/mostek	2	 OK
256	192.168.0.23	AC0B79	3 E kor k/mostek	2	 OK
257	192.168.0.23	AC0B8C	3 A kor k/302	2	 OK
258	192.168.0.23	ADE8CC	3 B kor k/318	2	 OK
259	192.168.0.23	ADE8DB	3 A kl. sch.	2	 OK
260	192.168.0.23	ADE974	3 E kor k/302	2	 OK
261	192.168.0.23	ADE984	3 B kor. k/302	2	 OK
262	192.168.0.23	AE6537	3 B kl. sch.	2	 OK
263	192.168.0.23	AE698D	3 B kor. k/312	2	 OK
264	192.168.0.23	AE750B	3 B kor k/320	2	 OK
265	192.168.0.23	AA1C7F	5 A SR XXXII	3	 OK
266	192.168.0.23	AA1CB7	4 E k kor/402	3	 OK
267	192.168.0.23	AA1CB9	4 E kor k/407	3	 OK
268	192.168.0.23	AA1CD1	5 A kor k/505	3	 OK
269	192.168.0.23	AA1F43	4 A kor k/pok406	3	 OK
270	192.168.0.23	AA1FF4	4 A kor k/432	3	 OK
271	192.168.0.23	AA1FFE	4 A kor k/403	3	 OK
272	192.168.0.23	AB05A1	4 A mostek	3	 OK
273	192.168.0.23	AB07BA	3 A kl. sch.	3	 Brak połączenia
274	192.168.0.23	AB091A	5 A spocznikPraw	3	 OK
275	192.168.0.23	AB0A58	4 A kor k/418	3	 OK
276	192.168.0.23	AB0EFC	5 A kor k/pok508	3	 OK
277	192.168.0.23	AB0EFD	4 E k kor/407	3	 OK
278	192.168.0.23	AB0F03	4 A kor k/407	3	 OK
279	192.168.0.23	AB0F05	4 A kor k/419	3	 OK
280	192.168.0.23	AB0F09	4 A kor k/426	3	 OK
281	192.168.0.23	AB0F0A	5 A kor k/502	3	 OK
282	192.168.0.23	AB0F11	4 E kor k/413	3	 OK
283	192.168.0.23	AB0F12	4 A kor k/416	3	 OK
284	192.168.0.23	AC0243	4 A spocznik pra	3	 OK
285	192.168.0.23	AC0359	4 E k kor/404	3	 Tryb awaryjny
286	192.168.0.23	AC0366	5 A spocznik L	3	 OK
287	192.168.0.23	AC03CC	4E kor/E412	3	 Brak połączenia
288	192.168.0.23	AC03D0	5 k.k/p.A508	3	 OK
289	192.168.0.23	AC03DC	4 A kor k/409	3	 OK
290	192.168.0.23	AC03DD	5 A kor k/kl.śr	3	 OK
291	192.168.0.23	AC03E5	4 E k kor/407	3	 OK
292	192.168.0.23	AC03E7	5 A kor k/503	3	 OK
293	192.168.0.23	AC0765	4 A kor k/428	3	 OK
294	192.168.0.23	AC07C6	4 A kor k/422	3	 OK











































Raporty Statusów Urządzeń

Lp.	Jednostka Sterująca	Urządzenie	Nazwa	Port	Status
295	192.168.0.23	AC07DE	4 A kl sch	3	 OK
296	192.168.0.23	AC0B18	4 E mostek	3	 Brak połączenia
297	192.168.0.23	AC0B25	5 A kl. sch. L	3	 OK
298	192.168.0.23	AC0B8A	5 A kor k/519	3	 Brak połączenia
299	192.168.0.23	ADE8D2	4 A spocznik pra	3	 OK
300	192.168.0.23	ADE8D3	5 A spocznik	3	 OK
301	192.168.0.23	AE74B3	5 A kl sch wej	3	 OK
302	192.168.0.23	AE74FE	5 A kor. k/526	3	 OK
303	192.168.0.23	AE7508	5 A kor. k/531	3	 OK
304	192.168.0.23	AE7509	5 A kor. k/528	3	 OK
305	192.168.0.23	AE750A	5 A kor. k/533	3	 OK
306	192.168.0.23	AF0E4D	5 A SR XXXII	3	 OK
307	192.168.0.23	AA1CC1	3 B kor k/333	2	 OK
308	192.168.0.23	AC03E8	0 A kor k/012	1	 OK
309	192.168.0.23	ADE980	3 E kor k/310	2	 OK
310	192.168.0.23	ADE977		1	 Brak połączenia
311	192.168.0.24	AA0993	1 B kor k/114	1	 OK
312	192.168.0.24	AA0EA7	1 B pok/137	1	 OK
313	192.168.0.24	AA1735	1 B pok/114	1	 OK
314	192.168.0.24	AA1BB6	1 s.rozpraw XI	1	 OK
315	192.168.0.24	AA1BB8	1 s.rozpraw X	1	 OK
316	192.168.0.24	AA1BBA	1 B pok/105	1	 OK
317	192.168.0.24	AA1BBB	1 B pok/103	1	 OK
318	192.168.0.24	AA1BC0	1 B pok/111	1	 OK
319	192.168.0.24	AA1BD1	1 s.rozpraw IX	1	 OK
320	192.168.0.24	AA1CBA	1 B kor k/105	1	 OK
321	192.168.0.24	AA1CC7	1 B kor k/A	1	 OK
322	192.168.0.24	AB05CE	0/1 B spocznik A	1	 OK
323	192.168.0.24	AB05DB	0/1 B spocznik	1	 OK
324	192.168.0.24	AB06F7	1 s.rozpraw XIII	1	 OK
325	192.168.0.24	AB07D2	1 kor k/s.r X	1	 OK
326	192.168.0.24	AB091D	1 B pok/108	1	 OK
327	192.168.0.24	AB0920	1 B pok/141	1	 OK
328	192.168.0.24	AB0921	1 B pok/105	1	 OK
329	192.168.0.24	AB0927	1 B pok/137	1	 OK
330	192.168.0.24	AB0E08	1 B pok konw.	1	 OK
331	192.168.0.24	AB0E14	1 B pok 121	1	 OK
332	192.168.0.24	AC023E	1 s. rozpraw IX	1	 OK
333	192.168.0.24	AC03BA	1 B kl sch. A	1	 OK
334	192.168.0.24	AC03BC	1 B kor k/113	1	 OK
335	192.168.0.24	AC03D3	1 B kor k/106	1	 OK
336	192.168.0.24	AC03DF	1 B kor k./128	1	 OK











































Raporty Statusów Urządzeń

Lp.	Jednostka Sterująca	Urządzenie	Nazwa	Port	Status
337	192.168.0.24	AC03E4	1 B kor k/109	1	 OK
338	192.168.0.24	AC03F5	1 s.rozpraw XIII	1	 OK
339	192.168.0.24	AC0753	1 B pok/114	1	 OK
340	192.168.0.24	AC0776	1 B pok/114	1	 OK
341	192.168.0.24	AC07D5	0/1 B spocznik A	1	 OK
342	192.168.0.24	AC0B13	1 B pok/111	1	 OK
343	192.168.0.24	AC0B34	1 B kor k/129	1	 OK
344	192.168.0.24	AC0B81	1 B kor k/142	1	 OK
345	192.168.0.24	ADE975	1 B pok/127	1	 OK
346	192.168.0.24	ADE978	1 B pok/128	1	 OK
347	192.168.0.24	ADE981	1 B kor k/109	1	 OK
348	192.168.0.24	ADE989	1 B kor k./117	1	 OK
349	192.168.0.24	AE67D9	1 B pok/127	1	 OK
350	192.168.0.24	AF1230	1 B kor k./111	1	 OK
351	192.168.0.24	AF1291	1 B kor k/WC	1	 OK
352	192.168.0.24	AF1292	1 B kl. sch.	1	 OK
353	192.168.0.24	AA140C	2 B pok/234	2	 OK
354	192.168.0.24	AA1BB5	1 B SR XXVI	2	 OK
355	192.168.0.24	AA1BB7	2 B pok/212	2	 OK
356	192.168.0.24	AA1BBF	2 B pok/230	2	 OK
357	192.168.0.24	AA1BBE	1 B kor	2	 OK
358	192.168.0.24	AA1BC2	2 B pok/206	2	 OK
359	192.168.0.24	AA1BC9	2 B pok/203	2	 OK
360	192.168.0.24	AA1BCA	2 B pok/206	2	 OK
361	192.168.0.24	AA1BCC	2 B pok/203	2	 OK
362	192.168.0.24	AA1BCE	2 B pok/226	2	 OK
363	192.168.0.24	AA1BD2	1 B SR XXVII	2	 OK
364	192.168.0.24	AA1BD3	2 B pok/212	2	 OK
365	192.168.0.24	AA1BD4	1 B SR XXVII	2	 OK
366	192.168.0.24	AA1CB1	2 B kor k/216	2	 OK
367	192.168.0.24	AA1CB5	2 B kor k/211	2	 OK
368	192.168.0.24	AA1CB6	1 B kor k/XXVII	2	 OK
369	192.168.0.24	AA1CC5	2 B kor k/kl.sch	2	 OK
370	192.168.0.24	AA1CCB	2 B łącznik A	2	 OK
371	192.168.0.24	AB05AC	2 B kor k/211	2	 OK
372	192.168.0.24	AB05BE	2 B pok/234	2	 OK
373	192.168.0.24	AB05BF	2 B pok/209	2	 OK
374	192.168.0.24	AB05CA	1 B spocznik k/A	2	 OK
375	192.168.0.24	AB05D1	2 B pok/230	2	 OK
376	192.168.0.24	AB05D8	2 B kor k/kl.sch	2	 OK
377	192.168.0.24	AB0A30	2 B kor k/211	2	 OK
378	192.168.0.24	AC023A	2 B pok/223	2	 OK










































Raporty Statusów Urządzeń

Lp.	Jednostka Sterująca	Urządzenie	Nazwa	Port	Status
379	192.168.0.24	AC023B	2 B pok/226	2	 OK
380	192.168.0.24	AC023D	2 B pok/215	2	 OK
381	192.168.0.24	AC023F	1 B kor k./203	2	 OK
382	192.168.0.24	AC0240	2 B pok/212	2	 OK
383	192.168.0.24	AC0241	1 B SR XXIV	2	 OK
384	192.168.0.24	AC035A	1 B kor k/XXIX	2	 OK
385	192.168.0.24	AC03B4	2 B kor k/221	2	 OK
386	192.168.0.24	AC03B9	2 B kor k/s.A	2	 OK
387	192.168.0.24	AC03D9	2 B kor k/235	2	 OK
388	192.168.0.24	AC03DA	2 B kor k/203	2	 OK
389	192.168.0.24	AC03F6	2 B kl. sch.	2	 OK
390	192.168.0.24	AC03FF	2 B pok/209	2	 OK
391	192.168.0.24	AC07D3	1/2 B spocznik	2	 Awaria źródła światła
392	192.168.0.24	ADE97D	1/2 B spocznik	2	 OK
393	192.168.0.24	ADE97F	2 B kor k/s.A	2	 OK
394	192.168.0.24	ADE988	1/2 B spocznik A	2	 OK
395	192.168.0.24	AA1508	4 B pok 414	3	 OK
396	192.168.0.24	AA1CCA	4 B kor k/434	3	 OK
397	192.168.0.24	AA1CD4	4 B kor k/431	3	 OK
398	192.168.0.24	AA1CDB	4 B kor k/415	3	 OK
399	192.168.0.24	AB05A8	4 B kor k/402	3	 Status nieznan
400	192.168.0.24	AB05B1	4 B pok 414	3	 OK
401	192.168.0.24	AB05C3	4 B spocz.kl/s	3	 OK
402	192.168.0.24	AB05C9	4 AB spocznik	3	 OK
403	192.168.0.24	AB05D2	4 B spocz.kl/s	3	 OK
404	192.168.0.24	AB05D9	4 B kor k/łA/B	3	 OK
405	192.168.0.24	AC025E	4 B kor k/kl/s	3	 OK
406	192.168.0.24	AC0362	4 B kor k/414	3	 OK
407	192.168.0.24	AC036A	4 B kor k/411	3	 OK
408	192.168.0.24	AC03B7	4 B kor k/420	3	 OK
409	192.168.0.24	AC03BD	4 B kor k/łA/B	3	 OK
410	192.168.0.24	AC03CD	4 B kor k/408	3	 OK
411	192.168.0.24	AC07E3	4 B kl/s	3	 OK
412	192.168.0.24	AC07E8	4 AB klatka sch	3	 OK
413	192.168.0.24	ADE8D5	4 AB spocznik	3	 OK
414	192.168.0.24	AE67B3	4 B kor k/425	3	 OK
415	192.168.0.24	AE698C	4 B kor k/434	3	 OK
416	192.168.0.24	AE74B6	4 B kor k/421	3	 OK
417	192.168.0.24	AE7505	4 B kor k/423	3	 OK
418	192.168.0.24	AC0408	0/1 B spocznik	1	 OK
419	192.168.0.24	ADE986	1 B pok/127	1	 OK
420	192.168.0.24	AA1BC8		2	 Brak połączenia

Raporty Statusów Urządzeń

Lp.	Jednostka Sterująca	Urządzenie	Nazwa	Port	Status
421	192.168.0.24	AA1BCD		2	 Brak połączenia
422	192.168.0.25	AA1734	2 SR nr XX	1	 OK
423	192.168.0.25	AA1888	2 A pok/209	1	 OK
424	192.168.0.25	AA1C80	2 A pok/209	1	 OK
425	192.168.0.25	AA1CCF	2 E kor k/211	1	 Tryb awaryjny
426	192.168.0.25	AA1CD8	2 E mostek	1	 OK
427	192.168.0.25	AA1CDA	2 E kor k/208	1	 OK
428	192.168.0.25	AA1FFF	2 A kl. sch. P	1	 OK
429	192.168.0.25	AB05B9	2 SR nr XIX	1	 OK
430	192.168.0.25	AB064E	2 A kor k/215	1	 OK
431	192.168.0.25	AB0914	2 A pok/202	1	 OK
432	192.168.0.25	AB0919	2/3 A spoczynnik L	1	 OK
433	192.168.0.25	AB091C	2 SR nr XVII	1	 OK
434	192.168.0.25	AB091E	4 A spoczynnik L	1	 OK
435	192.168.0.25	AB091F	2 SR nr XVI	1	 OK
436	192.168.0.25	AB0923	2 SR nr XV	1	 OK
437	192.168.0.25	AB0925	2 SR nr XVIII	1	 OK
438	192.168.0.25	AB0928	5 A kl. sch. L	1	 OK
439	192.168.0.25	AB0929	2/3 A spoczynnik P	1	 OK
440	192.168.0.25	AB092A	1/2 A spoczynnik P	1	 OK
441	192.168.0.25	AB0EF9	2 A kor k/212	1	 OK
442	192.168.0.25	AB0EFA	2 A kor k/217	1	 OK
443	192.168.0.25	AB0F00	2 A mostek	1	 OK
444	192.168.0.25	AB0F01	2 A kor k/208	1	 OK
445	192.168.0.25	AB2736	2 A kor k/202	1	 OK
446	192.168.0.25	AC037B	2 A kor k/209	1	 OK
447	192.168.0.25	AC0381	2 A kor k/208	1	 OK
448	192.168.0.25	AC0382	2 A kor k/213	1	 OK
449	192.168.0.25	AC03C1	2 E kor k/203	1	 OK
450	192.168.0.25	AC03F3	2 SR nr XVI	1	 OK
451	192.168.0.25	AC03FC	2 SR nr XX	1	 OK
452	192.168.0.25	AC03FD	2 SR nr XV	1	 OK
453	192.168.0.25	AC03FE	2 SR nr XV	1	 OK
454	192.168.0.25	AC0764	2 SR nr XIX	1	 OK
455	192.168.0.25	AC077B	2 SR nr XVII	1	 OK
456	192.168.0.25	AC079A	2 A pok/202	1	 OK
457	192.168.0.25	AC07B9	2 A pok/202	1	 OK
458	192.168.0.25	AC0C1A	2 E mostek	1	 OK
459	192.168.0.25	AC0C1E	2 E kor k/208	1	 OK
460	192.168.0.25	ADE8CE	2 A kl. sch. L	1	 OK
461	192.168.0.25	ADE8CF	4 A spoczynnik L	1	 Tryb awaryjny
462	192.168.0.25	ADE8D9	2/3 A spoczynnik L	1	 OK

Raporty Statusów Urządzeń

Lp.	Jednostka Sterująca	Urządzenie	Nazwa	Port	Status
463	192.168.0.25	ADE97E	2 E kor k/208	1	 OK
464	192.168.0.25	AE698B	2 A kor k/210	1	 OK
465	192.168.0.25	AE74AA	2/3 A spoczynnik P	1	 OK
466	192.168.0.25	AE74AB	1/2 A spoczynnik P	1	 OK
467	192.168.0.25	AE74B2	2 SR nr XVIII	1	 OK
468	192.168.0.25	AE74B5	2 SR nr XIX	1	 OK
469	192.168.0.25	AA1CC6	1 E mostek	2	 OK
470	192.168.0.25	AA1CCD	1 E kor k/105	2	 OK
471	192.168.0.25	AA1CE0	1 E kor k/103	2	 Awaria źródła światła
472	192.168.0.25	AA1FF3	1 p.A101	2	 OK
473	192.168.0.25	AB05B5	1 Czytelnia akt	2	 OK
474	192.168.0.25	AB05C6	1 A pok/120	2	 OK
475	192.168.0.25	AB05D7	1 A pok/113	2	 OK
476	192.168.0.25	AB07D4	1 A kor k/110	2	 OK
477	192.168.0.25	AB0EF8	1 A mostek	2	 OK
478	192.168.0.25	AB0F04	1 A kor k/108	2	 OK
479	192.168.0.25	AB0F07	1 A kor k/120	2	 OK
480	192.168.0.25	AB0F0D	1 A kor k/101	2	 OK
481	192.168.0.25	AB0F0F	1 A kor k/105	2	 OK
482	192.168.0.25	AC0246	0/1 A spoczynnik P	2	 OK
483	192.168.0.25	AC0363	1 A kl. sch. P	2	 OK
484	192.168.0.25	AC036F	1 A kor k/113	2	 OK
485	192.168.0.25	AC037A	1 A kor k/109	2	 OK
486	192.168.0.25	AC037F	1 A kor k/115	2	 Tryb awaryjny
487	192.168.0.25	AC0757	1 Czytelnia Akt	2	 OK
488	192.168.0.25	AC0767	1 A pok/113	2	 OK
489	192.168.0.25	AC0774	1 A pok/120	2	 OK
490	192.168.0.25	AC0778	1 Czytelnia Akt	2	 OK
491	192.168.0.25	AC079B	1 A pok/113	2	 OK
492	192.168.0.25	AC0B09	1 A spoczynnik L	2	 OK
493	192.168.0.25	AC0B10	1 E kor k/109	2	 OK
494	192.168.0.25	AC0B12	1 E kor k/108	2	 OK
495	192.168.0.25	AC0B78	1/2 A spoczynnik L	2	 OK
496	192.168.0.25	AC0C1D	1 E mostek	2	 Brak połączenia
497	192.168.0.25	AC0EFF	1 E kor k/108	2	 OK
498	192.168.0.25	ADE8FB	1 A kor k/110	2	 OK
499	192.168.0.25	ADE98D	1 A kl. sch. L	2	 OK
500	192.168.0.25	ADE991	0/1 A spoczynnik P	2	 OK
501	192.168.0.25	ADE992	1/2 A spoczynnik L	2	 OK
502	192.168.0.25	AE67B8	1 E kor k/114	2	 OK
503	192.168.0.25	AF0E57	1 A spoczynnik L	2	 OK

